



# Certificate of Compliance

This certificate is issued for the following:

## Polyethylene (PE) Pipe and Fittings for Underground Fire Protection Service

Model No	Product Description	Nominal Pipe Size, mm	Rated Working Pressure	
			bar	(psi)
Pipe	SDR9	110, 125, 140, 160, 180, 200, 225, 250, 280, 315, 355, 400, 450, 500, 560, 630	13.8	(200)
Pipe	SDR9	110, 125, 140, 160, 180, 200, 225, 250, 280, 315, 355, 400, 450, 500, 560, 630	15.9	(230)
Pipe	SDR11	110, 125, 140, 160, 180, 200, 225, 250, 280, 315, 355, 400, 450, 500, 560, 630	10.3	(150)
Pipe	SDR11	110, 125, 140, 160, 180, 200, 225, 250, 280, 315, 355, 400, 450, 500, 560, 630	12.1	(175)

**Prepared for:**

Nan Ya Plastics Corp  
201 Tung Hwa N. Rd, Taipei  
Taiwan, ROC

Approval Standard: 1613 (February 2017)

Approval Identification: PR455238

Approval Granted: January 21, 2022

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, appearing to read 'D.B. Fuller', is written over a horizontal line.

David B. Fuller  
VP, Manager – Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062

